



Declaration

Issued	30-10-2015	Scope	---
Report	150401376/4	Page	1 of 1
PIN	0476CQ1376		

Kiwa Cermet Italia hereby attests that the central heating boilers:

Trade mark:
Logo



Model: Mynute Green 35 R.S.I. E

is covered by the CE type certificate for the Directive on appliances burning gaseous fuels 2009/142/EC.

Appliance type: B_{23P}, B_{53P}, C₁₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃,
C_{13x}, C_{33x}, C_{43x}, C_{53x}, C_{63x}, C_{83x}, C_{93x}

Gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	Esi	20/25	Ls	13
H	20;25	Lw	20	P	30;37;50

The above gas groups can be combined according to the standard EN437:2009 and national situation of countries.

and been tested according to:

- EN 483:1999
- EN 483/A2:2001
- EN 483/A4:2007
- EN 483/AC:2006
- EN 677:1998

The present declaration doesn't substitute the EC certificate.
This declaration is valid until withdrawal or replacement of the above mentioned EC certificate

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità secondaria
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it
www.kiwacermet.it

Industry Division Manager
Maurizio Lorenzon



Number	KIP-15012/E	Replaces	---
Issued	30-10-2015	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	150401376/4	Page	2 of 2
PIN	0476CQ1376		

EC TYPE EXAMINATION CERTIFICATE

ANNEX 1

Model:

	Mynute Green 35 R.S.I. E
η_{100}	97,7 %
η_{30}	109,1 %
η_4	88,0 %
η_1	98,2 %
P_4	33,7 kW
P_1	n.t.
C.Heater?	No
B ₁ Boiler?	No
Type of boiler:	Condensing

Note:

η_{100} = At rated heat output and high-temperature regime - NCV (*)

η_{30} = At 30 % of rated heat output and low-temperature regime - NCV (**)

η_4 = At rated heat output and high-temperature regime - GCV (*)

η_1 = At 30 % of rated heat output and low-temperature regime - GCV (**)

P_4 = At rated heat output and high-temperature regime (*)

P_1 = At 30 % of rated heat output and low-temperature regime (**)

C.Heater = Combination heater (Yes = with domestic hot water production / No = Heating system only)

B₁ Boiler = B₁ according CEN/TR 1749:2014

Type of boiler = "Condensing Boiler" or "Low Temperature Boiler" or Other Boiler"

Efficiency's values have been measured with gas G20.

(n.t. = not tested)

Kiwa Cermet Italia S.p.A.

Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità secondaria

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).