



<b>Number</b>	KIP-17401/G	<b>Replaces</b>	--
<b>Issue date</b>	30-08-2023	<b>Contract number</b>	7230
<b>Due date</b>	29-08-2033	<b>Scope</b>	(EU) 2016/426 (9 March 2016)
<b>Report number</b>	2011765/2	<b>Module</b>	B (Type testing)
<b>PIN</b>	0476DN1765		

## EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

**MYNUTE EVO X 25C, MYNUTE EVO X 20R, EXCLUSIVE EVO X 25C, EXCLUSIVE EVO X 25R, MYNUTE EVO X 30C, MYNUTE EVO X 30R, EXCLUSIVE EVO X 30C, MYNUTE EVO X 35C, EXCLUSIVE EVO X 35C, EXCLUSIVE EVO X 35R**

Manufacturer

**RIELLO S.p.A.**  
**Via Ing. Pilade Riello, 7**  
**37045 Legnago (VR) - Italy**

Meet the essential requirements as described in the  
**Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.**

Reference standard: EN 15502-1:2021, EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

# CERTIFICATE

**Kiwa Cermet Italia S.p.A.**  
Società con socio unico, soggetta all'attività di  
direzione e coordinamento di Kiwa Italia  
Holding Srl

Via Cadriano, 23  
40057 Granarolo dell'Emilia (BO)

**Unità locale**

Via Treviso 32/34  
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: [info@kiwacermet.it](mailto:info@kiwacermet.it)

[www.kiwa.it](http://www.kiwa.it)

[www.kiwacermet.it](http://www.kiwacermet.it)

**GASTEC**

**President**

*Giampiero Belcredi*



PRD N° 069B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC  
Signatory of EA, IAF and ILAC Mutual Recognition Agreements



**Number** KIP-17401/G **Page** 1 of 2  
**Issue date** 30-08-2023 **Scope** (EU) 2016/426 (9 March 2016)  
**Due date** 29-08-2033 **Module** B (Type testing)  
**Report number** 2011765/2  
**PIN** 0476DN1765

## APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name: **BERETTA**

Types:

Model name	Nominal Heat Input - Qmax (Hi)	
	CH	DHW
	(kW)	(kW)
MYNUTE EVO X 20R	20,0	20,0
MYNUTE EVO X 25C	20,0	25,0
EXCLUSIVE EVO X 25C	20,0	25,0
EXCLUSIVE EVO X 25R	20,0	25,0
MYNUTE EVO X 30C	25,0	30,0
EXCLUSIVE EVO X 30C	25,0	30,0
MYNUTE EVO X 30R	30,0	34,9
MYNUTE EVO X 35C	30,0	34,9
EXCLUSIVE EVO X 35C	32,0	34,9
EXCLUSIVE EVO X 35R	32,0	34,9

Appliance types:

B23P, B53P, C13, C33, C43, C53, C63, C83, C93  
 C13x, C33x, C43x, C53x, C63x, C83x, C93x  
 C103\*

\* : Installation valid only for gas groups H and E

**Number** KIP-17401/G **Page** 2 of 2  
**Issue date** 30-08-2023 **Scope** (EU) 2016/426 (9 March 2016)  
**Due date** 29-08-2033 **Module** B (Type testing)  
**Report number** 2011765/2  
**PIN** 0476DN1765

## APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Countries:

AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	EY20	20	Ls	13
H	20;25	HY20	20;25	M	20
LL	20	Lw	20	P	30; 37; 50

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

Remarks:

Suffix "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H<sub>2</sub>) when the appliance is set for the reference gas G20.

All the boilers can be installed in a partially protected place (ambient temperature min / max -15°C / +60°C).

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.



<b>Number</b>	KIP-17401/E	<b>Replaces</b>	---
<b>Issue date</b>	30-08-2023	<b>Contract number</b>	I 7230
<b>Report number</b>	2011765/2	<b>Scope</b>	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
<b>PIN</b>	0476DN1765	<b>Module</b>	B (Type testing)

## EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the Central heating condensing boilers, type(s):

**MYNUTE EVO X 25C, MYNUTE EVO X 20R, EXCLUSIVE EVO X 25C, EXCLUSIVE EVO X 25R, MYNUTE EVO X 30C, MYNUTE EVO X 30R, EXCLUSIVE EVO X 30C, MYNUTE EVO X 35C, EXCLUSIVE EVO X 35C, EXCLUSIVE EVO X 35R**

Manufacturer

**RIELLO S.p.A.**  
**Via Ing. Pilade Riello, 7**  
**37045 Legnago (VR) - Italy**

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard: EN 15502-1:2021, EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

# CERTIFICATE

**Kiwa Cermet Italia S.p.A.**  
Società con socio unico, soggetta all'attività di  
direzione e coordinamento di Kiwa Italia  
Holding Srl

Via Cadriano, 23  
40057 Granarolo dell'Emilia (BO)

**Unità locale**

Via Treviso 32/34  
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: [info@kiwacermet.it](mailto:info@kiwacermet.it)

[www.kiwa.it](http://www.kiwa.it)

[www.kiwacermet.it](http://www.kiwacermet.it)

**GASTEC**

**President**

*Giampiero Belcredi*



PRD N° 069B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC  
Signatory of EA, IAF and ILAC Mutual Recognition Agreements



<b>Number</b>	KIP-17401/E	<b>Page</b>	1 of 7
<b>Issue date</b>	30-08-2023	<b>Scope</b>	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
<b>Report number</b>	2011765/2	<b>Module</b>	B (Type testing)
<b>PIN</b>	0476DN1765		

## APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:  
**BERETTA**

Specifications:  
Model(s):  
MYNUTE EVO X 20R, EXCLUSIVE EVO X 25R

Condensing boiler:	yes
Range rated:	no
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no <sup>(1)</sup>

<sup>(1)</sup> The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P <sub>4</sub>	19,5	kW
At 30 % of rated heat output and low-temperature regime (**)	P <sub>1</sub>	6,5	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η <sub>4</sub>	87,9	%
At 30 % of rated heat output and low-temperature regime (**)	η <sub>1</sub>	98,0	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η <sub>100</sub>	97,7	%
At 30 % of rated heat output and low-temperature regime (**)	η <sub>30</sub>	108,8	%

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)  
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.  
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

<b>Number</b>	KIP-17401/E	<b>Page</b>	2 of 7
<b>Issue date</b>	30-08-2023	<b>Scope</b>	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
<b>Report number</b>	2011765/2	<b>Module</b>	B (Type testing)
<b>PIN</b>	0476DN1765		

## APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:  
**BERETTA**

Specifications:  
Model(s):  
MYNUTE EVO X 25C, EXCLUSIVE EVO X 25C

Condensing boiler:	yes
Range rated:	no
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P <sub>4</sub>	19,5	kW
At 30 % of rated heat output and low-temperature regime (**)	P <sub>1</sub>	6,5	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η <sub>4</sub>	87,9	%
At 30 % of rated heat output and low-temperature regime (**)	η <sub>1</sub>	98,0	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η <sub>100</sub>	97,7	%
At 30 % of rated heat output and low-temperature regime (**)	η <sub>30</sub>	108,8	%

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)  
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.  
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

<b>Number</b>	KIP-17401/E	<b>Page</b>	3 of 7
<b>Issue date</b>	30-08-2023	<b>Scope</b>	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
<b>Report number</b>	2011765/2	<b>Module</b>	B (Type testing)
<b>PIN</b>	0476DN1765		

## APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:  
**BERETTA**

Specifications:  
Model(s):  
MYNUTE EVO X 30C, EXCLUSIVE EVO X 30C

Condensing boiler:	yes
Range rated:	no
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P <sub>4</sub>	24,4	kW
At 30 % of rated heat output and low-temperature regime (**)	P <sub>1</sub>	8,2	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η <sub>4</sub>	87,9	%
At 30 % of rated heat output and low-temperature regime (**)	η <sub>1</sub>	98,0	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η <sub>100</sub>	97,7	%
At 30 % of rated heat output and low-temperature regime (**)	η <sub>30</sub>	108,8	%

- (\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)  
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.  
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

<b>Number</b>	KIP-17401/E	<b>Page</b>	4 of 7
<b>Issue date</b>	30-08-2023	<b>Scope</b>	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
<b>Report number</b>	2011765/2	<b>Module</b>	B (Type testing)
<b>PIN</b>	0476DN1765		

## APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:  
**BERETTA**

Specifications:  
Model(s):  
MYNUTE EVO X 30R

Condensing boiler:	yes
Range rated:	no
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no <sup>(1)</sup>

<sup>(1)</sup> The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P <sub>4</sub>	29,3	kW
At 30 % of rated heat output and low-temperature regime (**)	P <sub>1</sub>	9,8	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	$\eta_4$	87,9	%
At 30 % of rated heat output and low-temperature regime (**)	$\eta_1$	97,9	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	$\eta_{100}$	97,6	%
At 30 % of rated heat output and low-temperature regime (**)	$\eta_{30}$	108,7	%

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)  
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.  
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.



<b>Number</b>	KIP-17401/E	<b>Page</b>	5 of 7
<b>Issue date</b>	30-08-2023	<b>Scope</b>	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
<b>Report number</b>	2011765/2	<b>Module</b>	B (Type testing)
<b>PIN</b>	0476DN1765		

## APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:  
**BERETTA**

Specifications:  
Model(s):  
MYNUTE EVO X 35C

Condensing boiler:	yes
Range rated:	no
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P <sub>4</sub>	29,3	kW
At 30 % of rated heat output and low-temperature regime (**)	P <sub>1</sub>	9,8	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η <sub>4</sub>	87,9	%
At 30 % of rated heat output and low-temperature regime (**)	η <sub>1</sub>	97,9	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η <sub>100</sub>	97,6	%
At 30 % of rated heat output and low-temperature regime (**)	η <sub>30</sub>	108,7	%

- (\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

*The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)  
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.  
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.*

<b>Number</b>	KIP-17401/E	<b>Page</b>	6 of 7
<b>Issue date</b>	30-08-2023	<b>Scope</b>	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
<b>Report number</b>	2011765/2	<b>Module</b>	B (Type testing)
<b>PIN</b>	0476DN1765		

## APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:

**BERETTA**

Specifications:

Model(s):  
EXCLUSIVE EVO X 35C

Condensing boiler:	yes
Range rated:	no
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P <sub>4</sub>	31,2	kW
At 30 % of rated heat output and low-temperature regime (**)	P <sub>1</sub>	10,4	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	$\eta_4$	87,8	%
At 30 % of rated heat output and low-temperature regime (**)	$\eta_1$	97,6	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	$\eta_{100}$	97,5	%
At 30 % of rated heat output and low-temperature regime (**)	$\eta_{30}$	108,4	%

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

<b>Number</b>	KIP-17401/E	<b>Page</b>	7 of 7
<b>Issue date</b>	30-08-2023	<b>Scope</b>	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
<b>Report number</b>	2011765/2	<b>Module</b>	B (Type testing)
<b>PIN</b>	0476DN1765		

## APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:  
**BERETTA**

Specifications:  
Model(s):  
EXCLUSIVE EVO X 35R

Condensing boiler:	yes
Range rated:	no
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no <sup>(1)</sup>

<sup>(1)</sup> The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P <sub>4</sub>	31,2	kW
At 30 % of rated heat output and low-temperature regime (**)	P <sub>1</sub>	10,4	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η <sub>4</sub>	87,8	%
At 30 % of rated heat output and low-temperature regime (**)	η <sub>1</sub>	97,6	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η <sub>100</sub>	97,5	%
At 30 % of rated heat output and low-temperature regime (**)	η <sub>30</sub>	108,4	%

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)  
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.  
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.